



VSB Vater & Sohn Brunnenbau GmbH
 Am Deich 1a
 01234 Wasserstadt
 Germany

Location
 Height: 63.00m
 UTM zone: 33U
 Right value: 412928
 High value: 5738670

Calculation of the
 extraction
 capacity
 according to VDI
 4640

Contractor VSB Vater & Sohn Brunnenbau GmbH

Depth from Depth up to	Petrographic designation / Moisture condition	thickness	spec. withdrawal capacity	Withdrawal performance
0.00m 0.10m	No material	0.10m		
0.10m 0.30m	Building rubble	0.20m		
0.30m 3.20m	Gravel, slightly moist	2.90m	70 W/m	203 W
3.20m 25.00m	Coarse gravel, Very wet	21.80m	80 W/m	1744 W
Total		24.70m		1947 W

List according to guideline VDI 4640 for 1800 annual operating hours