

		Brunnenbau Havelquell GmbH Quellweg 4 14938 Märkischheide Germany		Location Height: 30.00m UTM zone: 33U East value: 325706 North value: 5926382		
Pumping protocol		Client	Familie Schneider			
		Contractor	Brunnenbau Havelquell GmbH			
Site number				Designation of the borehole	Brunnen #1	
Performance period		12 Jun 2026 - 15 Jun 2026				
Type: Pump test Designation of the borehole: Pumpversuch #1						
Date & time		Pump capacity	Groundwater level			
	[sec]	[l/sec]	[m]			
10/07/2026, 12:30	0	46.00	3.10			
10/07/2026, 12:45	900	46.00	3.15			
10/07/2026, 13:00	900	46.00	3.28			
10/07/2026, 13:15	900	46.00	3.35			
10/07/2026, 13:30	900	45.00	3.42			
10/07/2026, 13:45	900	45.00	3.48			
10/07/2026, 14:00	900	44.00	3.55			
10/07/2026, 14:15	900	44.00	3.61			
10/07/2026, 14:30	900	44.00	3.67			
	7200					
Total duration: 2:00:00 Total flow rate: 324.00 m3						
Remarks		---				
Technician		Gerd Faber				
Signature of the technician		<i>Gerd Faber</i>				



Brunnenbau Havelquell GmbH
Quellweg 4
14938 Märkischheide
Germany

Pump diagram

Brunnen #1

Location
Height: 30.00m
UTM zone: 33U
East value: 325706
North value: 5926382

Type: Pump test

Measurement interval: 15 min

Designation of the borehole: Pumpversuch #1

